

Coliform Sampling Frequencies

Minimum Routine Disinfection and Flushing Frequency	Minimum Routine Coliform Sampling Frequency
At least 4 times per year = At least once within every three-month period (quarterly).	At least 1 time per year = At least once within every twelve-month period (annually)
At least 3 times per year = At least once within every four-month period.	At least 2 times per year = At least once within every six-month period (semi-annually)
At least 2 times per year = At least once within every six-month period (semi-annually)	At least 4 times per year = At least once within every three-month period (quarterly)
At least 1 time per year or less = At least once within every twelve month period (annually) or less.	At least 12 times per year = At least once every month (monthly)