Courtesy of:
Vannet Group, LLC

# Aircraft Drinking Water Rule Monitoring Decision Tree

PWS collects required ROUTINE samples

If a ROUTINE Sample is TC+/EC- then:

**#1-** Disinfect and Flush within 72hrs

OR

**#2-** Restrict Public Access within 72hrs; D&F "When Able"

OR

Collect 3 Repeat Samples w/in 24hrs

PN Must be Provided; Refer To Sections "A" To the right

If TC+/EC- Use either #1 Or #2 Options at left

If one or more Repeat Or Follow-up samples are TC+ & EC+

Collect Follow-up Samples Prior to providing water to the public

All Follow-Up Samples Are Negative

IF any Follow-Up Sample is TC+/EC-, Provide PN to CREW and PASSENGERS continue until all Follow-ups are TC-

Return To Routine Water System Usage, Return Access, & Return to Routine Monitoring

If one or more samples are TC+/EC+ then:

Restrict Public Access w/in 24hrs; Shut-off aircraft water system Where feasible

**SECTION A-1** If Unable to shut-off you must:

**SECTION A-2** If it can be shut-off you must:

Provide PN to CREW & PASSENGERS

AND

Provide Alternatives to water system (i.e. hand gels, etc)

Disinfect and Flush Within 72hrs

Provide PN to CREW

AND

Provide Alternatives to water system (i.e. hand gels, etc)

Disinfect and Flush When Able

Collect Follow-Up Samples

IF any Follow-Up Sample is TC+/EC- OR Is TC+/EC+, continue with same Corrective Action until all Follow-ups are TC-. Then allow access & return to routine monitoring.

866-616-8263 "Let Us Do The Work For You"